

Sand 0.55 - 0.65mm
Typical Lab Analysis

SIEVE	0.55 - 0.65 Sand
#16	89.6
#20	48.4
#25	21
#30	7.4
#35	2.1
#40	0.8
#50	0.1
Effective Size	0.62
Uniformity Coefficient	1.5
Specific Gravity	2.65
Loss on Ignition	Less than 4%
Acid Solubility	0.07%